



NOTES:

1. BONDING SHALL BE PROVIDED BETWEEN ALL ABOVE GROUND METALLIC POWER AND COMMUNICATION APPARATUS SEPARATED BY 6 FEET OR LESS. OPALCO PROVIDE/INSTALL GROUND RODS. OTHER UTILITIES TO PROVIDE/ENSURE BONDING GROUND WIRE BETWEEN APPARATUS AND GROUND RODS.
2. DRY UTILITIES SHALL BE INSTALLED IN A JOINT TRENCH, SEE DWG. U-4 AND U-5.

NO SCALE

	APPROVAL
	<i>Wayne R. Hayden</i>
PUBLIC WORKS DIRECTOR	
DATE 01/21/2022	
DRAWING NO. U-3	
REV:	

DRY UTILITY LAYOUT