



NOTES:

1. CONSTRUCT TRENCH IN COMPACTED LIFTS, POWER IN 1ST LIFT (6") PHONE LINE IN 2ND (4"), WATER IN 3RD (8"), TV IN 4TH, ETC. TO MAINTAIN VERTICAL SEPARATION FOR UTILITY LINES CROSSING W/IN TRENCH AND EXIT TO LATERAL TRENCHES.
2. PLACE UTILITY SPECIFIC WARNING TAPE AT 12" ABOVE HIGHEST UTILITY ABOVE EACH UTILITY.
3. PLACE SPOILS PILE AT 24" OFFSET FROM EDGE OF TRENCH.
4. MAINTAIN 12" MIN SEPARATION PRIMARY POWER TO OTHER UTILITIES.
5. MAINTAIN 24" MIN SEPARATION FROM WATER MAIN FOR PLACEMENT OF SADDLE.



APPROVAL

Wayne R. Hayden

PUBLIC WORKS DIRECTOR

**DRY UTILITIES AND
WATER MAIN SECTION**

DATE
01/21/2022
DRAWING NO.
U-4
REV:

NO SCALE