



NOTES:

1. PLACE PRIMARY DUCT AT BOTTOM OF TRENCH/EXCAVATION.
2. PLACE FIRST LIFT AROUND PRIMARY DUCTS AND LEVEL TO FORM PAD FOR TRANSFORMER VAULT.
3. PLACE SECONDARY/SERVICE LINES ABOVE FIRST LIFT BUT KEEP BELOW 30' FROM SURFACE.
4. DRIVE 10 FT GROUND ROD TO BELOW GRADE.

NO SCALE

 APPROVAL 	APPROVAL 	
	PUBLIC WORKS DIRECTOR DRY UTILITY SECTION	DATE 01/21/2022 DRAWING NO. U-6 REV: