



NOTES:

1. CLEANOUTS IN HARSCAPE SHALL BE BROUGHT TO GRADE PER STANDARD DWG S-10.
2. ALL PIPE MATERIAL SHALL BE BELL & SPIGOT TYPE WITH RUBBER GASKET JOINT OR GLUED JOINTS AND SHALL BE IN CONFORMANCE WITH ASTM D3034 (SDR-35).

NO SCALE



APPROVAL

Wayne R. Hayden

PUBLIC WORKS DIRECTOR

SIDE SEWER
HOUSE CONNECTION

DATE 01/21/2022	DRAWING NO. S-8
REV:	