




PLAN



PLAN



ELEVATION



ELEVATION

INSTALLED ON ASBESTOS CEMENT PIPE,
CAST IRON PIPE AND DUCTILE IRON PIPE.

INSTALLED ON ASBESTOS CEMENT PIPE,
CAST IRON PIPE AND DUCTILE IRON PIPE.

DUCTILE IRON
TAPPING SLEEVE

STAINLESS STEEL
TAPPING SLEEVE

NOTES:

1. STAINLESS STEEL TAPPING SLEEVES SHALL HAVE FULL CIRCLE SEAL.
2. ALL TEES AND VALVES TO BE WATER TESTED BEFORE TAP.
3. SIZE ON SIZE TAPS ALLOWED ONLY WITH DI MECHANICAL SLEEVE. ALL OTHER TAPS SHALL BE AT LEAST 2" SMALLER THAN THE EXISTING MAIN AND SHALL BE EPOXY COATED.
4. BRANCH LINE SHALL BE RESTRAINED AS IF A DEAD-END OR THRUST BLOCK PER DWG W-10

NO SCALE



APPROVAL

Wayne R. Hayden

PUBLIC WORKS DIRECTOR

DATE
01/21/2022

DRAWING NO.

W-11

REV:

TAPPING TEES