



NOTES:

1. GIL #101GHS BLOW-OFF.
2. 2" BRASS STREET "ELL".
3. 2" BRASS NIPPLE.
4. OLDCastle METER BOX CARSON 1118-12 BCF RECTANGLE HEAVY WALL BODY AND 1118BC DI FLUSH SOLID COVER.
5. 2" CAP NATIONAL STANDARD THREAD.
6. LOCK TO BE SUPPLIED BY TOWN.
7. VALVE BOX AND EXTENSION PER STANDARD DWG W-6.
8. HEAVY DUTY 2" GATE VALVE WITH RESILIENT SEAT GATE VALVES SHALL BE CLOW F-6103 THREADED ENDS OR TOWN APPROVED EQUAL.
9. ABOVE GROUND INSTALLATION MAY BE APPROVED BY THE TOWN.

NO SCALE

		APPROVAL
		<i>Wayne R. Haafle</i>
		PUBLIC WORKS DIRECTOR
END OF LINE BLOW-OFF ASSEMBLY		DATE 01/21/2022
		DRAWING NO. W-13
		REV: