



NOTES:

1. PAVEMENT MAY BE HOT MIX ASPHALT (HMA) OR PORTLAND CEMENT CONCRETE AS DETERMINED BY THE TOWN.
2. PAVEMENT, CRUSHED SURFACING TOP COURSE AND CRUSHED SURFACING BASE COURSE DEPTHS SHALL BE AS DETERMINED BY A PAVEMENT DESIGN COMPLETED BY A WASHINGTON STATE LICENSED ENGINEER.
3. SIDE SLOPES SHALL BE NO STEEPER THAN RATIOS SHOWN UNLESS RECOMMENDED BY A SOILS REPORT AND APPROVED BY THE TOWN. EXCAVATION SLOPES HIGHER THAN 8' SHALL BE DETERMINED BY SOILS TESTING.
4. IF ROAD GRADE IS LESS THAN .7% THEN CROSS SLOPE SHALL BE 3%.
5. 6" HIGH CEMENT CONCRETE PEDESTRIAN CURB WHERE REQUIRED BY TOWN.
6. SUBGRADE, AND CRUSHED SURFACING MATERIAL SHALL BE COMPAKTED TO A MINIMUM OF 95% OF THE MAXIMUM DRY DENSITY AS DETERMINED BY THE AASHTO T-180 TEST PROCEDURE.
7. HMA SHALL BE COMPAKTED TO A MINIMUM OF 91% OF THE THEORETICAL MAXIMUM DENSITY.
8. SIDEWALKS SHALL BE A MINIMUM OF 6' WIDE UNLESS DIRECTED OTHERWISE BY THE TOWN. WIDER SIDEWALKS WILL REDUCE OR ELIMINATE THE LANDSCAPE BUFFER WIDTH.
9. STREET TREES ARE REQUIRED ON BOTH SIDES OF THE STREET.

NO SCALE



APPROVAL

Wayne R. Hayden

PUBLIC WORKS DIRECTOR

MINOR ARTERIAL
60' RW STREET
SECTION

DATE
01/21/2022

DRAWING NO.

ST-2

REV: