



NOTES:

1. MAINTAIN 2" MINIMUM COVER ON ALL REBAR.
2. CONTRACTION JOINTS SHALL BE PLACED EVERY 15' AND AT ALL WALL RADII AND BEND POINTS. JOINT LOCATIONS TO MATCH SIDEWALK EXPANSION JOINTS LOCATIONS.
3. MODULAR BLOCK RETAINING WALL STANDARD BLOCK UNIT 8"x18"x21 1/2".
4. DRAIN PIPE TO CONNECT TO DOWNSTREAM STORM SYSTEM.
5. CONCRETE CAP SHALL BE CLASS 3000 PSI.
6. MODULAR BLOCK GRAVITY WALL EXPOSED HEIGHT IS 4' OR LESS.



APPROVAL

Wayne R. Haydon

PUBLIC WORKS DIRECTOR

**MODULAR BLOCK
RETAINING WALL
FILL SECTION**

DATE
01/21/2022

DRAWING NO.

ST-36

REV: