



## NOTES:

1. THE ENGINEER SHALL CONFIRM THAT THE FOUNDATION WILL BE EMBEDDED IN COMPETENT SOILS WITH A MINIMUM ALLOWABLE BEARING PRESSURE OF 1,500 PSF.
2. THE FOUNDATION SHALL BE LOCATED ON LEVEL GROUND OR AT LEAST 4 TIMES THE SHAFT DIAMETER AWAY FROM THE SLOPE.
3. IF PIER IS IN SIDEWALK, PLACE A 6-INCH DEEP BY 2 FOOT SQUARE CAP OVER PIER. TOP OF SQUARE PIER SHALL MATCH SIDEWALK ELEVATION.



APPROVAL

PUBLIC WORKS DIRECTOR

**LIGHT STANDARD  
FOUNDATION DETAIL**

DATE  
**01/21/2022**

DRAWING NO.

**ST-37**

REV: