

Town of Friday Harbor

2018 Consumer Confidence Report on Water Quality



Surface water is the sole source of water for those served by the Town of Friday Harbor. Trout Lake, the primary source, is about five and a half miles west of Town in an isolated, undeveloped pocket fed by a steep drainage basin. The Town owns 600 acres of the surrounding 840 acre watershed.

Distribution System: detected levels of Primary Standards

(see Acronyms and Definitions on page 2)

Parameter	MCL	MCLG	Maximum Reported Value	Range	Likely Source	Meets Regs?
Copper (¹)	Action Level: 90% of the homes tested must have copper levels less than 1.3 ppm	0 ppm	.425 ppm 2016 levels, tests required every 3 years	.025 to .425 ppm	Corrosion of household plumbing systems	Yes
Lead (¹)	Action Level: 90% of the homes tested must have lead levels less than .015 ppm	0 ppm	.002 ppm 2016 levels, tests required every 3 years	Not detected to .002 ppm	Corrosion of household plumbing systems	Yes
Total Trihalo-methanes (THMs)	80 ppb	0 ppb	38.4 average for 2017(²)	23.6 to 48.5 ppb	By-products of chlorination process	Yes ⁽³⁾

¹) Copper and lead are both naturally-occurring metals. Lead and copper have never been detected in the Town's source water. Both have been used to make household plumbing fixtures for many years, although Congress banned the installation of lead solder, pipes and fittings in 1986. The two contaminants get into drinking water when water reacts with these metals in pipes and fixtures. This is particularly likely to happen when water sits in pipes for more than a few hours. When lead or copper reach the action level in ten percent of the homes sampled, the water provider must begin certain water treatment steps.

The pH range of Friday Harbor water is 7.78 to 7.95 which lessens the corrosive potential of copper and lead. Until July 1998, WA State DOH required a random testing of ten homes once a year for the presence of copper and lead. The detection rates have been so low that these tests are now required every three years. The next testing date is July, 2019.

²) This test is performed once a quarter in the distribution system. Because the test results are averaged over four consecutive quarters, some values in the range may be higher than the maximum reported value.

³) In 2017 the THM yearly average was well below the MCL. Some people who drink water containing THMs over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. THM's are formed when organics in the water come in contact with chlorine. We have implemented Granular activated carbon technology which has significantly reduced THMs. **Please see page 4 for Friday Harbor's efforts regarding Trihalomethane Removal.** If you would like more information about THM's please call us at 360-378-8353.

Acronyms and Definitions

Action Level

The concentration of a contaminant which, if exceeded, triggers a treatment technique or other requirement which a water system must follow.

Cryptosporidium

A tiny organism that is associated with the disease cryptosporidiosis. This disease can be transmitted by swallowing the organism in contaminated water or food, person-to-person contact, or other exposure routes.

EPA

Environmental Protection Agency. A federal level agency.

Fecal Coliform

Fecal coliforms and *E.coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes.

Giardia

A tiny organism that is associated with the disease giardiasis. Swallowing this organism in contaminated food or water, exposure from person-to-person contact, and other exposure routes may cause this disease.

Hardness

Hardness is an indication of the amount of dissolved minerals in water. Friday Harbor water has a range of hardness values from 80-100 ppm, which is considered "medium soft."

Inorganic Chemicals

Examples include things like metals, minerals and salts.

MCL

Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best treatment technology.

MCLG

Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

ND

Not Detected.

NTU

Nephelometric Turbidity Unit. Unit of measure used to describe water clarity.

PAH

Polyaromatic Hydrocarbons. A group of Synthetic Organic Compounds that are tested for.

pH

Indicates whether a liquid is acidic or basic. Friday Harbor water has a pH range of 7.0 to 8.3 which lessens the corrosive potential of copper and lead.

ppb

parts per billion. One ppb is approximately equal to 1 drop of water in a 22,000 gallon swimming pool.

ppm

parts per million. The same as mg/l (milligram per liter). One ppm is approximately equal to 1 drop of water in 22 gallons.

Primary Standards

Legally-enforceable standards that apply to public water systems. Primary standards limit the levels of specific contaminants that can adversely affect public health and are known or are anticipated to occur in water.

Secondary Standards

Non-enforceable guidelines regarding contaminants that may cause cosmetic effects, such as tooth discoloration, or aesthetic effects, such as taste, color or odor, in drinking water.

SRL

State Regulatory Level. Standards that are set by WA State DOH and may supersede federal levels.

SOC

Synthetic Organic Chemicals. Examples include such things as weed killers, fertilizers and bug spray.

Total Coliform

A group of bacteria that can be naturally present in the environment and are used as an indicator that other, potentially harmful bacteria may be present.

Treatment Technique

A required process intended to reduce the level of a contaminant in drinking water. A treatment technique may be required by the EPA or WA State DOH.

Turbidity

Describes how cloudy the water is. The smaller the number, the clearer the water. Turbidity has no health effects, however, it can interfere with disinfection and provide a medium for microbial growth.

VOC

Volatile Organic Chemicals. Examples include things like petroleum-based chemicals, industrial by-products and dry cleaning solvents.

WA State DOH

Washington State Department of Health.

CCR Contact:

Mike Deegan

Water System Manager

360-378-8353

tfhwater@fridayharbor.org

In 2017 the Town's water system produced 116,028,000 gallons with system leakage of 5,914,508 gallons. Unaccounted-for water at the end of 2017 was 5.1%. This was accomplished by early leak detection technology and meter replacement. The Town of Friday Harbor's goal is to reduce unaccounted-for water. Authorized consumption will be reduced through consumer education and aging main replacement. Through conservation efforts we saved approximately 2.1 million gallons in 2017 compared to 2016. The Town of Friday Harbor Waste Water Treatment Facility completed an effluent water recovery system in the Spring of 2008. Water consumption at the Waste Water Treatment Facility is down from 530,000 gallons in 2016 to 300,100 gallons in 2017. We are currently implementing leak detection, meter replacement, a low flush toilet rebate program, consumer education, and replacement of aging mains in the distribution system. In 2016 and 2017 we replaced 5 miles of transmission main from the plant and new transmission pipe from the dam to the treatment plant eliminating undetectable leaks.

The DOH advises that all drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). Some people may be more vulnerable to drinking water contaminants than the general population. Immuno-compromised persons, such as people with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/ Centers for Disease Control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available at www.epa.gov/safewater or from the Safe Drinking Water Hotline (800) 426-4791.

Improvements to the Town Water System

The Town of Friday Harbor replaced 7 miles of asbestos transmission pipe in 2017. Although this type of pipe does not pose a health threat, after 50 years of service the time had come to upgrade to newer virtually indestructible high density polyethylene or HDPE (PE) pipe. HDPE's outstanding performance means that consumers get the very best, cleanest water possible. Because other pipes leak, more electricity is needed to process and pump additional water.

Three platforms known as solar bees were deployed in Trout Lake in 2006. Solar Bee's use long distance circulation to solve water quality problems in fresh water lakes and reservoirs and provide significant energy savings by relying on solar power. They also eliminate the need for toxic chemicals. The Solar Bee is a floating solar-powered lake, and reservoir circulator. The Solar Bee draws water up from below and spreads it gently across the top of the water body for continuous surface renewal.

Each Solar Bee unit can displace and mix 10,000 GPM in freshwater reservoirs. The energy savings from each unit is the equivalent to about 220,000 kW hrs per year, or the annual energy requirements for about 20 homes. This reduces carbon dioxide emissions (the leading Greenhouse Gas, GHG) by about 150 tons per year. Solar Bee's long distance circulation greatly accelerates the biological and chemical processes that clean up fresh water, and potable water. The high efficiency Solar Bee circulation can reduce up to 80% of the chemical requirements in potable water systems. Solar bees eliminate the need for algaecides and herbicides, as well as phosphorus-binding compounds such as alum.

The Town of Friday Harbor received top honors for providing some of the clearest drinking water in the State for three consecutive years. The Washington State Department of Health (DOH) presents the Treatment Optimization Program (TOP) Award to water purveyors that meet significantly higher water quality standards than those set by the government. Steve Deem of the Washington State DOH presented the award at Town Hall in 2016. The Town is one of only eleven systems in the state to receive this year's Bronze award. We are currently on course to achieve the Silver award for a six year span for continued water quality standards in accordance with the Treatment Optimization Program.

The Town's water department voluntarily participates in the stringent DOH program which challenges operators to exceed the minimum legal standards for three consecutive years. According to Town Public Works Director Wayne Haefele, the DOH has set an extremely difficult goal. "It requires that water systems make the TOP goal a priority in everything we do and every decision we make," said Haefele. TOP Award winners must maintain extreme water clarity, known as low "turbidity", while simultaneously complying with every other measurement of water quality without exception for three consecutive years. Turbidity is considered one of the most dependable tests for confirming the removal of potential pathogenic organisms from water.

Trout Lake Treatment Plant: detected levels of Primary Standards

(see Acronyms and Definitions on page 2)

Parameter	MCL	MCLG	Maximum Reported Value	Range	Likely Source	Meets Regs?
Turbidity (⁴)	0.5 NTU	Not applicable	.27 NTU Highest monthly average occurred 11/ 2017	.04 to 0.27 NTU Based on daily samples	Erosion of soils	Yes 100% of samples met turbidity limits

⁴) Turbidity has no health effects, however turbidity can interfere with disinfection and provide a medium for microbial growth. Washington State Department of Health requires treatment facilities to provide full filtration and disinfection.

NOTICE TO WATER SYSTEM USERS ANNUAL NITRATE MONITORING VIOLATION DECLARATION

We, Friday Harbor Water system ID# 26595 in San Juan County are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. The June 2017 testing was delayed until March of 2018. Historically nitrates have never been detected in our water supply. Nitrate samples for March 2018 were reported as non-detectable in our water supply as did the 2016 results. As a result of the complications concerning the 2017 sampling, we have implemented a stringent double check plan to insure that this is an isolated instance.

Trihalomethane Removal Since the new granular activated carbon (GAC) filters were put on-line in 2011 the Friday Harbor Water Utility has achieved the goal of significant reduction of the amount of trihalomethane acids (THM). With this highly effective organic removal system, the Water Utility now reports a 2017 average of only 38.40 ppb, well below the current MCL allowable limit of 80 ppb. The GAC filter's purpose is to capture organics in the water, preventing a chemical reaction with chlorine that creates a disinfected byproduct known as trihalomethane acids.

- Primary standards limit the levels of specific contaminants that can adversely affect public health and are known or are anticipated to occur in water. As of 2018 all levels of Primary Standards were below the MCL or non detectable in the Trout Lake Treatment water shed. Based on this and previous sampling, the Washington State Department of Health waived reporting through December 2024.
- The following substances were tested for but not detected or below the MCL:

Volatile Organics - In 2018 these substances were not detected. The Town received a waiver until 10/24 of no need to test. Herbicides are tested once every 3 years. The results from 01/15 warranted a State waiver for no testing for Synthetic Organic testing through 2019. Inorganics are tested every 9 years per State waiver based on the results from 12/11. The Town continues to test for other substances including pesticides, and radiological substances which are currently nonexistent in our water.

